



Object: \_\_\_\_\_  
 Customer: \_\_\_\_\_  
 Contact person: \_\_\_\_\_

**Total flow rate:** \_\_\_\_\_ m<sup>3</sup>/h

- Sizing Collector/Distributor:**
- SAVE 97 ≤ 7.9 m<sup>3</sup>/h\*
  - SAVE 125 ≤ 19.6 m<sup>3</sup>/h\*
  - SAVE 180 ≤ 48.4 m<sup>3</sup>/h\*
  - SAVE 250 ≤ 118.4 m<sup>3</sup>/h\*

**Collector/distributor**  
 Number of connections 12-36 pcs: \_\_\_\_\_ Connections  ø 32  
 (e.g. 12 pcs = 12x flow + 12x return)  ø 40  
 ø 50

**Main outlet outer diameter:** ø \_\_\_\_\_ mm

- Flow-collector, from the probe:** (in accordance with SIA)
- Inline-Setter (5-42 l/min)
  - Inline-Setter (20-70 l/min)
  - Hyline-Setter (10-25 l/min)
  - Hyline-Setter (20-60 l/min)
  - Ball valve

**Return-distributor, to the probe:** (in accordance with SIA)  Ball valve

- Air vent:**  Autom.  Manual  No  
**Butterfly valve for main outlet:**  Yes  No

- Cover (class):**
- A15 bolted
  - B125 bolted
  - D400 supplied loose

- Options:**
- Thermomanometer
  - Lighting tube lamp
  - Dome sealing against groundwater
  - Level adjustment on site
- \* ṽ max. [m<sup>3</sup>/h] @ 1m/s